

Connect collector to pump group

Secure collector with clamps

Insulate pipes with UV- and temperature-resistant insulation

Set collector direction

Install service valves and air vents

Connect supply and return pipes

Install temperature sensor in the sensor housing

Route solar pipes

Stage 4. Hydraulic Connections

Connect to storage tank / heat exchanger

Place collector on structure

Stage 3. Collector Installation

1.

2.

3.

4.

5.

6.

7.

8.

9.

10.

11.

12.